



NOTES:

1. ALL PVC SANITARY SEWER SHALL BE MARKED BY 6" MAGNETIC DETECTABLE TAPE, LABELED "CAUTION SEWER LINE BELOW" (OR APPROVED EQUAL). DETECTION TAPE TO BE CENTERED ABOVE PIPE AND BURIED BETWEEN 6" AND 12" BELOW FINAL GRADE.
2. DUCTILE IRON PIPE SHALL BE USED FOR ALL GRAVITY SANITARY SEWER MAINS AND SERVICE LATERALS BURIED DEEPER THAN 16 FEET AS MEASURED FROM THE TOP OF THE PIPE TO FINISHED GRADE ELEVATION.



SAB
APPROVED BY:

KFM
DRAWN BY:

DATE: 10/23/2018

PVC PIPE BACKFILL WITH DETECTION TAPE

DURHAM COUNTY, NORTH CAROLINA
ENGINEERING DEPARTMENT

SCALE:
NTS

DETAIL NO.
DUCO - 010