



NOTES:

1. ALL CONCRETE SHALL BE 3600 PSI.
2. ALL JOINTS ARE TO BE SEALED WATER TIGHT.
3. WEIR IS TO BE POURED-IN-PLACE CONCRETE.
4. REFER TO NCDOT STANDARD DRAWINGS FOR BOX CONSTRUCTION.
5. NOT ACCEPTABLE FOR USE IN STREET RIGHT OF WAY WITHOUT CDOT/NCDOT APPROVAL.

NOT TO SCALE



COUNTY OF DURHAM, NC  
ENGINEERING DEPARTMENT  
STORMWATER DETAIL

FLOW SPLITTER STRUCTURE

BMP FIG. 4.1.11